intertek
caleb brett

Preliminary Report of Analysis

AmSpec Services, LLC
Ian Leito
14682 Airline Highway
Destrehan, LA 70047
United States of America

Our Reference Number: NA100-0008320
Lab Reference Number: 2025-CURA-000069
Customer Reference Number: Analysis Only

Customer Product Description: ULSD
Location: Curacao, Curacao, , Netherlands Antilles
Sample Representing: Shore Tank 08 Average After Discharge
Drawn By: Client

Sample ID: 2025-CURA-000069-006
Date Sampled: 24-May-2025
Date Submitted: 24-May-2025
Date Tested: 13-Jun-2025

	Method	Property	Result	Units	Min	Max	P/F
	ASTM D445	Kinematic Viscosity at 40 °C	3.021	mm²/s	2.0	4.1	Pass
	ASTM D4052	API Gravity @ 60°F	39.3	°API	32.0		Pass
		Density @ 15°C	828.2	kg/m³	820	845	Pass
		Specific Gravity @ 60°F	0.8286				
	ASTM D976	Cetane Index	56.5		46.0		Pass
	ASTM D5453	Sulfur Content	6.7	ppm Wt		15	Pass
	ASTM D93	Corrected Flash Point	67.0	°C	60.0		Pass
3	ASTM D664	Acid Number	0.06	mg KOH/g		0.50	Pass
3	ASTM D2274	Total Insolubles (Oxidation Stability)	1	mg/L		25	Pass
	ASTM D4530	Micro Method Carbon Residue 10%	<0.1	Wt %		0.3	Pass
	ASTM D2500	Cloud Point	-6	°C			
	ASTM D97	Pour Point	-9	°C		0	Pass
	ASTM D4176 MOD	Appearance	Clear & Bright		Clear and Bright		Pass
	ASTM D482	Ash	<0.010	Wt %		0.010	Pass
	ASTM D6079	Major Axis	360	µm			
		Minor Axis	340	µm			
		Wear Scar Diameter	350	µm		460	Pass
	ASTM D86	Initial Boiling Point	174.0	°C			
		10% Recovery	218.0	°C			
		50% Recovery	276.0	°C		288.0	Pass
		90% Recovery	332.0	°C	282.0	338.0	Pass
		Final Boiling Point	361.0	°C			
		Residue	1.0	% Vol		2.0	Pass
		Loss	0.5	% Vol		2.0	Pass
	ASTM D1500	ASTM Color	0.5		<= 2.5		Pass
2	ASTM D130	Copper Corrosion @ 50°C (122°F)/3 hr	1a			Max No. 3	Pass
2	ASTM D613	Cetane Number	57.5		46.0		Pass
2	ASTM D1319	Aromatics	18.8	Vol %		35.0	Pass
2	EN 12662	Total Contamination	<12.0	mg/kg		24.0	Pass
2	ASTM D7111	Silicon	<0.10	mg/kg			
3	ASTM D2624	Temperature	21.0	°C			
		Electrical Conductivity	214	pS/m	25		Pass

intertek
caleb brett

Preliminary Report of Analysis

Our Reference Number: NA100-0008320
Lab Reference Number: 2025-CURA-000069
Customer Reference Number: Analysis Only

Customer Product Description:	ULSD	**Sample ID:**	2025-CURA-000069-006
Location:	Curacao, Curacao, , Netherlands Antilles	**Date Sampled:**	24-May-2025
Sample Representing:	Shore Tank 08 Average After Discharge	**Date Submitted:**	24-May-2025
Drawn By:	Client	**Date Tested:**	13-Jun-2025

	Method	Property	Result	Units	Min	Max	P/F
	ASTM D95	Water Content	<0.01	Vol %		0.02	Pass
2	EN 12916	Polycyclic-Aromatic Hydrocarbons	Pending	%(m/m)		8.0	
2	EN 16576	Manganese	<0.50	mg/L			
2	ASTM D7359	Total Chlorine	<1.0	mg/kg			

Material conforms to the Curoil ULSD requirements on above relevant point(s) of testing.

The issuance of this document does not exonerate any party from exercising all their rights and discharging all their liabilities under any contract of Sale. Stipulations to the contrary are not binding upon Intertek Oil, Chemical & Agri. Intertek Oil, Chemical & Agri responsibility is limited to gross negligence proven, and will in no case be more than ten times any fees or commission. All activities are undertaken on the basis of the applicable Intertek Oil, Chemical & Agri Terms and Conditions of Service. Nor should attempt to use or rely upon the contents of this document without having read and understood the Terms and Conditions applicable thereto. A copy can be obtained at http://www.intertek.com/terms.

The information contained herein is based on laboratory tests and observations performed by Intertek. The sample was submitted by Amspec Curacao N.V. solely for testing. Intertek disclaims any and all liability for damage or injury which might result from the use of the information contained herein, and nothing contained herein shall constitute a guarantee, warranty on representation by Intertek with respect to the accuracy of the information, the sample, product or item described, or its suitability for use for any specific purpose.

The analysis results denoted by (3) were performed by CRU Refinery laboratory. Intertek cannot accept liability for the accuracy of any results not performed by its own laboratories.

The analysis results denoted by (2) were performed by Intertek Deer Park

This report has been reviewed for accuracy, completeness, and comparison against specifications when available. The reported results are only representative of the samples submitted for testing and are subject to confirmation upon completion of the final report, which may contain warnings, exceptions and terms and conditions which are pertinent to the data supplied herein. It is the position of Intertek that the final report is the prevailing document, and that the use of interim documents by the client is at their own risk. This report shall not be reproduced except in full without written approval of the laboratory.

Results are only representative of the sample tested. All tests have been performed using the latest version unless otherwise indicated. This report shall not be reproduced except in full without written approval of Intertek. Report is subject to our standard Terms and Conditions which can be obtained at our website : http://www.intertek.com/terms

The sample was submitted for testing purposes. Intertek cannot accept liability for the representativeness of the sample.

Signed By: _____ Date: 13-Jun-2025

Glenn Gustina, Branch Coordinator