intertek
caleb brett

Report of Analysis

Curacao Oil N. V. (Curoil)
Excon Martina
A.M Chumanceiro Blvd.15,
P.O. Box 3927
Willemstad
Netherlands Antilles

Our Reference Number: NA100-0008782
Lab Reference Number: 2026-CURA-000116
Customer Reference Number: Energy Apollo

Customer Product Description: ULSD
Location: Prins Hendrik Wharf, Curacao, , Netherlands Antilles
Sample Representing: Shore Tank 06 U,M,L, Average After Discharge
Drawn By: Intertek

Sample ID: 2026-CURA-000116-002
Date Sampled: 04-Aug-2026
Date Submitted: 04-Aug-2026
Date Tested: 15-Aug-2026

	Method	Property	Result	Units	Min	Max	P/F
	ASTM D445	Kinematic Viscosity at 40 °C	2.237	mm²/s	2.0	4.1	Pass
	ASTM D4052	API Gravity @ 60°F	37.4	°API	32.0		Pass
		Density @ 15°C	837.3	kg/m³	820	845	Pass
		Specific Gravity @ 60°F	0.8377				
	ASTM D976	Cetane Index	47.3		46.0		Pass
	ASTM D2622	Sulfur Content	9.2	ppm Wt		15	Pass
	ASTM D93	Flash Point	62.5	°C	60.0		Pass
	ASTM D664	Acid Number	0.12	mg KOH/g		0.50	Pass
2	ASTM D2274	Total Insolubles (Oxidation Stability)	1	<<<g/m³		25	Pass
	ASTM D4530	Micro Method Carbon Residue 10% Distillation Residue	<0.1	Wt %		0.3	Pass
	ASTM D2500	Cloud Point	-15	°C			
	ASTM D97	Pour Point	<-24	°C		0	Pass
	ASTM D4176 MOD	Appearance	Clear & Bright		Clear and Bright		Pass
	ASTM D482	Ash	<0.010	Wt %		0.010	Pass
	ASTM D6079	Major Axis	430	µm			
		Minor Axis	380	µm			
		Wear Scar Diameter	400	µm		460	Pass
	ASTM D86	Initial Boiling Point	167.0	°C			
		10% Recovery	193.0	°C			
		50% Recovery	250.0	°C		288.0	Pass
		90% Recovery	320.0	°C	282.0	338.0	Pass
		Final Boiling Point	357.0	°C			
		Residue	1.0	% Vol		2.0	Pass
		Loss	1.0	% Vol		2.0	Pass
	ASTM D1500	ASTM Color	0.5		<= 2.5		Pass
2	ASTM D130	Copper Corrosion @ 50°C (122°F)/3 hr	1a		Max No. 3		Pass
2	ASTM D1319	Aromatics	28.0	Vol %		35.0	Pass
2	EN 12662	Total Contamination	<12.0	mg/kg		24.0	Pass
2	ASTM D7111	Silicon	<0.10	mg/kg			
	ASTM D2624	Temperature	24.0	°C			
		Electrical Conductivity	55	pS/m	25		Pass
	ASTM D95	Water Content	0.00	Vol %			
2	ASTM D6890	Derived Cetane Number (DCN)	47.9				
2	EN 12916	Polycyclic Aromatic Hydrocarbons (Proc A)	3.6	%(m/m)			

intertek
caleb brett

Report of Analysis

Our Reference Number: NA100-0008782
Lab Reference Number: 2026-CURA-000116
Customer Reference Number: Energy Apollo

Customer Product Description:	ULSD	**Sample ID:**	2026-CURA-000116-002
Location:	Prins Hendrik Wharf, Curacao, , Netherlands Antilles	**Date Sampled:**	04-Aug-2026
Sample Representing:	Shore Tank 06 U,M,L, Average After Discharge	**Date Submitted:**	04-Aug-2026
Drawn By:	Intertek	**Date Tested:**	15-Aug-2026

	Method	Property	Result	Units	Min	Max	P/F
2	EN 16576	Manganese Content	<1.00	mg/L			
2	ASTM D7359	Total Chlorine	<1.0	mg/kg			

Material conforms to the Curoil ULSD requirements on above relevant point(s) of testing.

The issuance of this document does not exonerate any party from exercising all their rights and discharging all their liabilities under any contract of Sale. Stipulations to the contrary are not binding upon Intertek Oil, Chemical & Agri. Intertek Oil, Chemical & Agri responsibility is limited to gross negligence proven, and will in no case be more than ten times any fees or commission. All activities are undertaken on the basis of the applicable Intertek Oil, Chemical & Agri Terms and Conditions of Service. Nor should attempt to use or rely upon the contents of this document without having read and understood the Terms and Conditions applicable thereto. A copy can be obtained at http://www.intertek.com/terms.

The analysis results denoted by (2) were performed by Intertek Suriname laboratory.

Results are only representative of the sample tested. All tests have been performed using the latest version unless otherwise indicated. This report shall not be reproduced except in full without written approval of Intertek. Report is subject to our standard Terms and Conditions which can be obtained at our website : http://www.intertek.com/terms

Signed: O. Henriquez Date: 15-Aug-2026

Otmar Henriquez, Laboratory Technician